



Jim Doyle, Governor
Mary P. Burke, Secretary

July 11, 2007

LEDGEVIEW PRECAST CONCRETE, INC.
ALLEN E. FREUND
N6672 COUNTY TRUNK UU
FOND DU LAC WI 54935

Re: Description: SEWAGE TREATMENT APPARATUS (also see SEWAGE TANKS)
Manufacturer: LEDGEVIEW PRECAST CONCRETE, INC.
Product Name: MICROFAST 0.5/PUMP, 0.75/PUMP, 0.9/PUMP, 1.5/PUMP & HIGH STRENGTH FAST
1.0/PUMP
Model Number(s): 2000 2-COMPARTMENT
Product File No: 20070333

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of July 2012.

This approval supersedes the approval issued on September 4, 2003, under product file number 2030411.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20030411.

This approval is contingent upon compliance with the following stipulation(s):

- This tank may only be used when installed with the Bio-Microbics, Inc., High Strength or Micro Fast sewage treatment apparatus.
- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- This product is recognized to treat a maximum of 1.0 pound of BOD5 per day at a maximum daily wastewater flow of 500 gallons per day.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE
Plumbing Product Reviewer
phone: 608-266-6742
fax: 608-267-9566
e-mail: mike.beckwith@wisconsin.gov
SBD-10564-E (N.10/97)